



# COUNTY OF LOS ANGELES

## DEPARTMENT OF PUBLIC WORKS

900 SOUTH FREMONT AVENUE  
ALHAMBRA, CALIFORNIA 91803-1331  
Telephone: (818) 458-5100

THOMAS A. TIDEMANSON, Director

ADDRESS ALL CORRESPONDENCE TO:  
P.O. BOX 1460  
ALHAMBRA, CALIFORNIA 91802-1460

July 30, 1990

IN REPLY PLEASE  
REFER TO FILE:

Mr. Jerry Apodaca  
13703 E. Lanning Drive  
Whittier, California 90605

Dear Mr. Apodaca:

### EXPANSIVE SOIL POOL DECK REQUIREMENTS


I have reviewed the swimming pool plan that you furnished, for deck requirements in expansive soil.

The plan requires a deck with a minimum width of four feet and all joints in this deck to have a permanent resilient waterproof seal.

Your property is in an expansive soil area which would require the deck and seal.

Very truly yours,

T. A. TIDEMANSON  
Director of Public Works

  
Donald D. Martin  
District Engineer  
Building and Safety Division

DDM:jf